



Circuit

Unattended - Timed automatic stop with push/pull valve (Start/interrupt stop) or detented stop

CAUTION:



Minimum time required for filling the reservoir.

NOTES:

- Clean dry non-lubricated air to be used.
- Timers should never be adjusted while in operation.
- Pressures should not exceed timer specification.

This circuit has been designed as a concept/theory only. It is your responsibility to ensure that these details comply will all safety standards and regulations. We cannot accept responsibility for its application. Pneumatic cylinders have been used to illustrate output functionality only. Schematic diagrams shown here may vary from actual parts supplied, although functionality will remain the same.

Impulse Automation Limited	Date: 13th May 2014 Drawing: DWG007	REVISION	3
<p>Title: Pneumatic Single Shot Timing Circuit with Latched Stop Button</p> <p>www.impulseautomation.co.uk sales@impulseautomation.co.uk</p>		Author: Robert Dunn	
			