


Unattended - Single shot dual timed output circuit with push/pull valve (Start/Stop)

CAUTION:

 Upon applying air system may start automatically.

NOTES:

Clean dry non-lubricated air to be used.
Timers should never be adjusted while in operation.
Pressures should not exceed timer specification.

These circuits have been designed as a concept/theory only. It is your responsibility to ensure that these details comply will all safety standards and regulations. We cannot accept responsibility for its application. Schematic diagrams shown here may vary from actual parts supplied, although functionality will remain the same.

Impulse Automation Limited

Date: 13th May 2014
Document: DWG010

REVISION

3

Author: Robert Dunn

Title: Single Shot Dual Output Pneumatic Timing Circuit

www.impulseautomation.co.uk
sales@impulseautomation.co.uk

